SCALA 1:1



10

SCALA 1:1



01

SCALA 1:1



06

SCALA 1:1



05

SCALA 1:1



04

SCALA 1:1



03

SCALA 1:1



02

SCALA 2:1



07

SCALA 2:1



08



SCALA 4:1

09

Pos.	Denominazione	Q.	Materiale	Norme	Note
1	Serbatoio	1	Acc.34 Cr Mo4	UNI7845	verniciato rosso
2	Supporto	1	Acc.TeP12		Zinc Cod.
3	Corpo diffusore	1	Materiali vari		
4	Flexcorte	1	P.V.C.		
5	Manopola	1	Materiali vari		
6	Valvola erogatrice	1	Materiali vari		
7	Spinotto di sicurezza	1	TSnZ-V61-4N	UNI EN 10181	
8	Sigillo	1	P.V.C.		
9	Tappo di sicurezza	1	Nichelato	UNI EN 12164	
10	Estintore (prospetto)	1	Materiali vari		

1	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
2	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
3	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
4	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
5	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
6	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]

STUDIO TECNICO CARINI
VIA BORGONUOVO N° 16-20
ISOLA DEL LIRI
TEL. 0776/814391
FAX. 0776/814799
Email: studio@marilenecarini.it

COMMITTENTE:

GI.BI. Estintori
20023 CERRO MAGGIORE (MI) ITALY

OGGETTO: PK5
ESTINTORE PORTATILE A CO2
(BIOSSIDO DI CARBONIO) DA 5KG

Elaborato: 002
File: [illegible]

TAVOLA: PARTICOLARI
DISPOSITIVI EROGATORI, DISPOSITIVI DI SICUREZZA
SERBATOIO, CORPO VALVOLA

Scala: VARIE
Tolleranza gen.: ±0,5 mm

Disegnato	Controllato	Approvato	REV
R.G.	Geom./Ing. CARINI		0003
Il Tecnico	Il Supervisore	La Committente	Data:
Dott.Ing./Architetto CARINI	Dott.Ing./Architetto CARINI	G.B.I. srl	06-10-05

Proprietà riservata. Non può essere riprodotto o comunicato a terzi senza autorizzazione scritta.