

**TYPE APPROVAL CERTIFICATE**  
No. FPE374504CS/2



**This is to certify** that the product identified below is in compliance with the applicable requirements of the RINA type approval system.


<i>Description</i>	<b>Portable Fire Extinguisher</b>
<i>Type</i>	<b>PS 2</b>
<i>Applicant</i>	<b>GIBI ESTINTORI SRL VIALE KENNEDY 20023 CERRO MAGGIORE (MI) ITALIA</b>
<i>Manufacturer</i>	<b>GIBI ESTINTORI SRL</b>
<i>Place of manufacture</i>	<b>VIALE KENNEDY 20023 CERRO MAGGIORE (MI) ITALIA</b>
<i>Reference standards</i>	<b>RINA rules for portable fire extinguishers</b>

Issued in **Genoa** on **September 9, 2004**. This Certificate is valid until **September 8, 2009**

  
\_\_\_\_\_  
RINA

**Franca Parisi**

This certificate consists of this page and 1 enclosure





**FPE374504CS/2**  
**Enclosure - Page 1 of 1**  
**PS 2**

**Manufacturer and place of production**

Gibi Estintori S.r.l.  
Viale Kennedy  
20023 Cerro Maggiore (MI)  
ITALY

**Product description**

Cylinder material	Steel
Outside cylinder diameter	110 mm approx.
Minimum wall thickness	1.5 mm
Cylinder capacity	2.00 dm <sup>3</sup>
Weight empty	1.540 kg approx.
Weight full	3.540 kg approx.
Working pressure at 20°C	1.3 N/mm <sup>2</sup>
Extinguishing agent	2 kg Powder ABC type "Centrimax ABC 40 Blue"
Fire rating	13A - 89B - C

**Field of application**

Portable fire extinguishers in compliance with Chapter 4 Sect. E (Fire Protection) RINA Rules for the construction and classification of pleasure vessels

**Reference documents**

Gibi Estintori Drawings approved by RINA on 21/02/1994

**Tests carried out**

RINA type and extinction tests. Report n° 99DGDP116 - P2S dated 05.08.1999

**Remarks**

Mass produced articles (Containers of mass produced articles) of the aforesaid material are to be marked or labelled with the trade name and the data of the Company to whom this Certificate is addressed. The validity of this Certificate is dependent on the compliance of each manufactured product with the prototype which underwent the type approval tests and such compliance shall be stated by the manufacturer. Moreover, the Company is fully responsible for ensuring compliance by performing all the necessary checks also in respect of its sub-suppliers. Notwithstanding the above, RINA reserves the right to make any checks it deems appropriate during production. The validity of this Certificate ceases in the case of amendments to the rules on the basis of which the Certificate was issued.

**09/09/2004**

